

# Datasheet Sensiblu 315

Rev 04 date 2014.02.18



|                        |  |
|------------------------|--|
| Flow                   | 3 - 15 l / min , 150 – 900l/ h                                     |
| Active Chlorine        | 0,20 – 0,40 mg / l   |
| Max working pressure   | 8 Bar, prevent water hammer  |
| Maintenance            | Salt Refill required after 30.000 litre, use Sensiblu Refill units |
| Water inlet and outlet | 3/4 " BSPT   |

Incoming water requirements for optimal production of active Chlorine:

|               |                                   |
|---------------|-----------------------------------|
| pH            | < 7,8                             |
| Prefiltration | 100 micron (preferably 40 micron) |
| Hardness      | < 30 dH , < 50 fH                 |
| Organics      | KMnO4 < 5 ppm                     |
| Iron          | < 1 ppm                           |
| Temperature   | 5 – 40 degree C                   |

